

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 8140-2137:0501 Page 1 of 1

CATEGORY: Exterior Wall Siding And Sheathing For Wildland Urban Interface (W.U.I)

LISTEE: Swanson Group Mfg. LLC, 1651 South F Street, Springfield, OR 97478
Contact: Ken Pratt (360) 791-9408 Fax (541) 832-1213
Email: ken.pratt@swansongroup.biz

DESIGN: Douglas-fir Front and Back Veneer Plywood, nominal 19/32" thick with 4", 6", or 8" groove lengths, direct-attached. Panel is a 5-ply, 5-layer 19/32" plywood system with front, back, and center veneers of Douglas-fir, in sizes 4' x 8', 4' x 9', or 4' x 10'. Installed on nominal 2" x 4" studs, 16" O.C. Siding was fastened to the studs at 6" spacing on edge and 12" spacing in the field with 6d nails.

Refer to manufacturer's installation instructions and product data sheets.

RATING: SFM 12-7A-1

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and SFM label.

APPROVAL: Listed as exterior wall siding for use in the Wildland Urban Interface areas. Refer to listee's Installation Instruction Manual for details.

NOTE: Test Protocol SFM 12-7A-1

4-28-21 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **May 04, 2021**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO,, M.E., F.P.E.**
Fire Engineering Division